

APPENDIX D
LEAD-BASED PAINT SURVEY SUMMARY
MCKINNEY GROUP C PARCELS

**LEAD-BASED PAINT SURVEY SUMMARY
MCKINNEY GR UP C PARCELS**

Patton Park

Patton Park Housing Area 2A/2Q was surveyed for LBP. Buildings in the Patton Park Housing Area 2A/2Q that are included in the McKinney Group C Parcel are: Buildings 8704 through 8708, 8717 through 8727, and 8736 through 8742. Fifty-six representative buildings in the Patton Park Housing Area 2A/2Q were tested for lead-based paint (LBP). The following components tested positive for LBP: kitchen windowsills, bathroom walls, bathroom doors, bathroom door frames, bathroom windowsills, bathroom closet floors, bedroom windowsills, living area windowsills, house exterior (stucco and wood), exterior wood trim, exterior wood fences (if painted), exterior doors, exterior door frames, rain gutters/downspouts, outdoor storage area, porch partition (wood), carport fascia.

On the basis of this testing, it is presumed that all 23 buildings listed above contain LBP.

Abrams Park

Abrams Park Housing Area IN was surveyed for LBP. Buildings in the Abrams Park Housing Area IN that are included in the McKinney C Parcel are 6111, 6112, 6113, and 6114.

Sixty-three representative buildings were tested for LBP in the Abrams Park Housing Area IN. No components tested positive for LBP.

On the basis of this testing, it is presumed that the four buildings listed above do not contain LBP.

Reference: Industrial Hygiene Survey No. 55-71-R25A-94, 1 Nov. 93 - 11 Mar 94 (AEHA, 1994)

DISTRIBUTION

Environmental Baseline Survey
McKinney Homeless Act
Group C Parcels
Former Fort Ord, California

Version 2

February 29, 1996

Copy No. 14

Copies 1 - 18: Mr. Dan McMIndes
 Department of the Army
 Corps of Engineers
 Sacramento District
 1325 J Street
 Sacramento, California 95814-2922

Copies 19 - 22: Harding Lawson Associates

Quality Control Reviewer



Christopher R. Smith, R.G. 4619
Principal Hydrogeologist

SMF/CRS/vj/A42625-H