

**APPENDIX D**  
**LEAD-BASED PAINT SURVEY SUMMARY**

**APPENDIX D  
LEAD-BASED PAINT SURVEY SUMMARY**

Industrial Hygiene Survey No.  
55-71-R25A-94, 1 Nov. 93 - 11 Mar 94  
(AEHA, 1994)

**Korean Barracks**

Buildings in the Korean barracks housing area that are in the CSUMB parcel are:  
Buildings 4554, 4556, 4558, 4564, 4566, 4568, 4580, 4582, 4584, 4586, 4590, 4592, 4594, 4596, 4782, 4784, 4786, 4792, 4794, 4796, 4798.

The following buildings were tested for LBP: 4556, 4582, 4596, 4782, 4792, 4798.

The following components tested positive for lead-based paint:

- Occupant room walls
- Occupant room doors
- Interior stairwells
- Interior stairwell handrails
- Exterior handrails
- Exterior door frames
- Exterior stairs/steps (risers)